PLOT PLAN 1" = APPROX. 200'



510 - HOOSIC
313 - DEERFIELD
538 - SQUAMSCOTT
134 - MAYBID

SOIL CLASS: 510, 313, 538, 134
SOURCE: USDA-SCS SOIL SURVEY

BENCH MARKS:
#1 TOP OF I. PIN @ NE LOT COR EL. 119.71
#2 TOP OF I. PIN @ SE LOT COR EL. 125.35
(DATUM APPROX USGS PER PLAN NOTE A)

DESIGN INTENT:
BED BOTTOM TO BE PLACED
1.8' ABOVE
EXISTING GRADE, UPSLOPE SIDE (EL 120.7)

SUITABLE REPLACEMENT AREA:
IN PLACE OR REDESIGN

KEY:
_____ EXISTING CONTOUR
- - - - - - - - - - PROPOSED CONTOUR
100.0 EXISTING SPOT ELEVATION
(100.0) PROPOSED SPOT ELEVATION

(PROPOSED GRADING SHOWN ONLY AS IT PERTAINS TO SEPTIC SYSTEM DESIGN)

NOTES:
1. SUBDIVISION APPROVAL #35673-A
2. THIS SYSTEM IS NOT DESIGNED TO HANDLE GARBAGE DISPOSAL WASTE

LOCUS MAP NO SCALE





CROSS SECTION — NO SCALE



4 LINE SYSTEM

PLAN — 1" = 20'



NOTE A: SEE "TOPOGRAPHIC PLAN FOR STANLEY SIUDAK IN NEWMARKET, N.H. SCALE 1"=50' JUNE 1987, REVISED APR 1988, PARKER SURVEY ASSOC., INC, EXETER & SEABROOK, NH"

* TEST PIT DATA BY PARKER SURVEY (SEE NOTE A)

TEST PIT DATA DATE: 4/29/87



PERC TEST DATE: 4/29/87

DEPTH OF HOLE: 30"
RATE OF PERC: * 5 MIN/IN BY PARKER SURVEY (SEE NOTE A)
DESIGN LOADING: 3 BEDROOMS
AREA REQUIRED: 646 SQ. FT.
PROPOSED SYSTEM: 20 × 40 FOR 800 SQ. FT. AREA PROVIDED

REVIEWED AND APPROVED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NEW HAMPSHIRE WATER SUPPLY & POLLUTION CONTROL COMMISSION
Signed Kim Morgan
Date 3-25-87

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES IN PLANS AS INDICATED ON THIS CONDITIONAL APPROVAL

PLAN OF PROPOSED SEPTIC SYSTEM

LOCUS: LOT 3 BALD HILL ROAD
NEWMARKET, N.H. 171912

OWNER: DONALD & DOROTHY TAFT
C/o GORSKI ASSOC
PO BOX 563, EXETER, NH 03833

APPLICANT: STOCKTON SERVICES
PO BOX 1306
HAMPTON, N.H. 03842
DESIGNER PERMIT #348

DATE: 2/17/89 REVISED 3/23/89

APPROVAL: 171910

109

NEW HAMPSHIRE Designer of Subsurface Disposal Systems — Ann W. Balobreski No. 348 — Water Supply & Pollution Control

RECEIVED MAR 21 1989 WATER SUPPLY AND POLLUTION CONTROL